

FORM – V
(See rule 14)

Environmental statement for the financial year ending the 31st March 2009

PART – A

1.	Name and address of the Owner/Occupier of the Industry, operation of the process.	:	BINANI CEMENT LIMITED, THERMAL POWER PLANT (NEW – 25 MW) BINANIGRAM, PINDWARA, DIST. SIROHI, RAJASTHAN, PIN – 307 025
2.	Industry category	:	RED, LARGE
3.	Production Capacity	:	25 MW
4.	Year of establishment	:	31ST MARCH 2008
5.	Date of the last environmental statement submitted	:	Nil (This is the first Environment Statement of this project)

PART – B

Water and Raw Material Consumption

(I) Water consumption in m3/day.

Process	:	Nil
Cooling	:	153.20 (Run Days considered as 143.2)
Domestic	:	2.0 (Run Days considered as 365)

Name of products	Process Water consumption per unit of product output	
	During the previous financial year	During the current financial year
	(1)	(2)
Electric Power	-	0.3489 KL/MWH

(II) Raw Material consumption

S. No.	Name of raw material	Name of products	Consumption of raw material per unit output (Per Tonne)	
			During the previous financial year	During the current financial year
1.	Coal & Lignite as fuel	Electric Power	-	0.8047 MWH/MT

PART – C

Pollution discharged to environment/unit of output generated (Parameter as specified in the consent issued)

S. No.	Pollutants	Concentration of Pollutants in discharge	Percentage of variation from prescribed standards with reason.			
a.	Water (Industrial)	Cooling Tower Blow Down (Average Values for the year 2008-09)		No variation. All parameters are within the prescribed limits stipulated by concerned regulatory authorities.		
		Parameter	Prescribed Std. (mg/Ltr.)		Observed Value (mg/Ltr.)	
		Free available Chlorine	0.5		0.10	
		Zinc	1.0		0.10	
		Chromium (Total)	0.2		NT	
		Phosphate	5.0		1.60	
		Boiler Blow Down (Average Values for the year 2008-09)			No variation. All parameters are within the prescribed limits stipulated by concerned regulatory authorities.	
		Parameter	Prescribed Std. (mg/Ltr.)			Observed Value (mg/Ltr.)
		Suspended Solids	100			52.75
		Oil & Grease	20			8.38
	Copper as Cu	1.0	NT			
	Iron as Fe	1.0	0.15			
	Water (Domestic)	Domestic sewage treatment plant in colony (Common for Cement Plant, CPP & Mines) (Average Values for the year 2008-09)		No variation. All parameters are within the prescribed limits stipulated by concerned regulatory authorities.		
		Parameter	Prescribed Std. (mg/Ltr.)		Observed Value (mg/Ltr.)	
pH		5.5 – 9.0	7.61			
TSS		100	59.41			
BOD		30	17.14			
COD		250	95.41			
Oil & Grease	10	4.93				
b.	Air (Stack emission) Particulate matter	SPM emission from Boiler Stack (Average Value for the year 2008-09)		No variation. All parameters are within the prescribed limits stipulated by concerned regulatory authorities.		
		Stack	Prescribed Standard (mg/Nm3.)		Observed Value (mg/Nm3.)	
		Boiler (25 MW)	100		33.30	

PART - D

Hazardous Wastes

(As specified under Hazardous Wastes (Management and Handling) Rules, 2003) & recently amended as Hazardous Waste (Management, Handling & Transboundary Movement) Rules, 2008

S. No.	Hazardous Waste	Total quantity (Kg.)	
		During the previous financial year	During the current financial year
a.	From Process		
	Used Oil & Grease (Kg)	-	19717*
b.	From pollution control facility	-	No any

* Total quantity generated from all the components (Cement Plant, CPPs & Mines)

PART – E

Solid Waste

Sl. No.	Solid Waste	Total quantity	
		During the previous financial year	During the current financial year
a.	From Process (Bottom Ash)	-	1513.23 MT
b.	From pollution control facility (Fly Ash)	-	6030.18 MT
c.	Quantity recycled or reutilized (Fly Ash including Bottom Ash)	-	7543.41 MT

Note: Entire fly ash (incl. bottom ash) generated in CPP, was utilized in cement manufacturing process.

PART – F

Please specify the characterization (in terms of composition & quantum) of hazardous as well as solid wastes and indicate disposal practice adopted for both these categories of wastes.

(i) Hazardous Waste (generated from the entire premises):

Description of Haz. waste	Qty. of waste generated during the year (Ltr.)	Discharged from	Accumulated quantity (as on 01.01.2009)	Disposal Method	Equipment / Facility Used
Used/ Spent Oil & Grease	21095* (Ltr.)	19717* (Ltr.)	5067 (Ltr.)	Burnt in cement Kiln	Mixed with coal & fired in Kiln

* Total quantity generated from all the components (Cement Plant, CPPs & Mines)

(ii) Other Solid Waste (generated from the entire premises):

Description of waste	Qty. of waste generated during the year (MT)	Disposed (MT)	Accumulated quantity (as on 01.04.09)	Disposal Method	Equipment / Facility Used
Screen Reject (Mines)	413619	413619**	Nil	*	Earmarked dump yards
Fly Ash (purchased)	323973	333223	Nil	Used in PPC production	Fly Ash feeding system & Cement Mill
Fly Ash (from CPP)	33125.78	33125.78	Nil	Used in PPC production	Fly Ash feeding system & Cement Mill
Bottom Ash (from CPP)	2780.04	2780.04	Nil		
STP Sludge	10.0	10.0	Nil	Composting	Used in plantation
Household (Kitchen) waste	182.50	182.50	Nil	Dumped in pits for Composting	Dumpsite maintained by local municipality
Paper Waste	10.0	10.0	Nil	Used in Kiln as fuel	Kiln
Metal Scrap	1121.02	1121.02	Nil	Sold to recyclers	-
Rubber Scrap	16.04	16.04	Nil	Sold to recyclers	-
Torn PP Bags & other misc. lastic Waste	57.43	57.43	Nil	Sold to Mfr./ authorized recyclers	-
Refractory Waste	871.90	871.90	Nil	Sold to authorized recyclers	-
E-waste (Old computers, printers, circuit boards etc.)	25 (Nos)	25 (Nos)	Nil	Buy Back system	-
Spent Batteries	95 (Nos.)	95 (Nos.)	Nil	Buy Back system	-
Filter bags scrap	1400 (Nos)	1400 (Nos)	Nil	Sold thru tender (for recycling)	-
Cotton waste	6.38	6.38	Nil	Used in Kiln as fuel	Kiln
Wooden Scrap	69.68	69.68	Nil	Sold thru Tender (for recycling /reuse)	-

**Screen reject is scientifically stacked in benches (in Mines) & plantation is done to prevent erosion.

PART – G

Impact of the pollution abatement measures taken on conservation of natural resources and on the cost of production.

The plant is equipped with state-of-the-art Air Pollution Control devices such as ESP & Jet Pulse Filters designed to control the emission (SPM) level below 50 mg/Nm³ through the stack attached to the boiler.

In addition, we are successfully managing the ambient SPM level to below the prescribed levels by way of putting up Jet Pulse Filters at each of the transfer points, fully mechanized system for Fly Ash handling, covered belt conveyors, water sprinklers of raw material & coal conveyors and mostly paved surfaces for vehicular movement inside the plant premises.

All these systems have proved to be very effective in arresting and putting back the recovered material into the production line thus preventing the precious raw material, fuel, intermediate & finished products from getting lost in the atmosphere.

Additionally, over the years, the company has undertaken various energy efficiency improvement measures & process modifications which helped to significantly reduce the overall energy consumption to enable us to achieve our ultimate goal of GHG emission reduction and positive contribution towards reversing the effects of Climate Change.

Thus, the pollution abatement & other energy conservation practices adopted by us save precious raw material/ product and greatly help in conserving valuable natural resources.

PART – H

Additional measures/ investment proposal for environmental protection including abatement of pollution / prevention of pollution.

- (a) Use of 5% of the alternative fuel in both the kilns by replacing fossil fuels (coal/ lignite)
- (b) Modification and performance improvement of colony STP
- (c) Plantation of 5000 nos. of tree saplings in 09-10.
- (d) Complete refurbishing of the first field of Cooler -1 ESP to further improve its efficiency / performance.
- (e) Construction of 2 more water harvesting structures in 09-10.
- (f) Replacement of cooling water pumps with energy efficient pumps.
- (g) Replacement of 70W street lights with CFL to reduce energy consumption and increase the illumination level.
- (h) Installation of Power Boss in the motors with variable load in belt conveyors of raw material feeding for conservation of energy.
- (i) Installation of power saving schemes in street lights in colony after midnight.
- (j) Installation of High Tension capacitors in the main incomer and load centre for improving the power factor.
- (k) Installation of vacuum cleaning system at packing plant.

PART – I

Any other particulars for improving the quality of the environment.

Details of steps taken for improvement of environment during 08-09 (Common for cement plant, mines & CPP)

Environment Management System improvement

1. Recent review of Management policy to exert greater emphasis on conservation of natural resources in particular water and non renewable energy sources.
2. Periodical review of EMS including compliance of environmental laws through periodic Management Review & Quality forums
3. Quarterly EHS inspection of all the sections including the Contractors' Premises throughout the plant premises.
4. Awareness promotion through various environmental competitions, workshops, presentations etc. on world environment day, Earth Day, Bio-diversity Day, Ozone Layer Conservation Day etc.

(i) AIR

(A) Improvement in Ambient Air Quality through effective control on fugitive dust emission

- (a) **Concrete paving in 2000 M2** plant area in Unit-I & Unit-II resulting in effective control on air born fugitive dust due to vehicular movement.
- (b) Replacement of **2388 Nos. of filter bags** in bag filters (JPF) to effectively control the dust emission during material transport to improve the air quality inside the plant premises.

(B) Reduction in point source emission

- (a) Installation of state-of-the-art Dry Fly Ash feeding system to facilitate direct unloading of open fly ash trucks as well as closed tankers, thus remarkably minimizing fugitive emission caused during fly ash handling.
- (b) Replacement of existing hemi-centric valves with improved dome valves to **avoid ESP tripping** due to high hopper level resulting in reduction in stack emission from CPP-1 Boiler stack.

(ii) WATER

(a) Reduction in water consumption /tonne of cement

Specific Water consumption for last 3 years:

Consumption	2006-07	2007-08	2008-09
Water (M3 per ton of cement)	0.13	0.19	0.12

(b) Augmenting the groundwater resources

Constructed 6 more water harvesting structures (Check dams) in Amlu Mines during the year 08-09 thus increasing the water harvesting potential to 1.61 MCM @ an annual average rainfall of 705 mm.

(c) Sewage Treatment Plant

Modification/ renovation of colony STP to further improve its performance and efficiency.

(iii) Green Belt development

5010 tree saplings were planted in Plant, Colony & mines during **08-09** covering an area of around 5 hectares. Thus the total nos. of surviving plants at the end of 08-09 is **116726**.

In addition to above, 3 new **garden development** projects were also undertaken at the following sites:

1. Near old project office
2. Near shopping centre & new club building in colony
3. Complete renovation of the Municipal Park at the tehsil H.Q.

Company has planned to plant 5000 tree saplings during the year 09-10.

(iv) Reduction in Noise Level

Some of the major initiatives taken to reduce the noise level are as under:

1. Installation of **new generation turbine** with covered components in CPP-III. The average noise level of this turbine is 15 dB less than that of conventional turbines.
2. Fixing of **rubber pads** beneath CM-3 liners resulted in average 3 dB noise reduction.

(v) Increase in industrial waste utilization

▪ Raw material

1. Continue to replace **5%** of mineral gypsum in cement grinding with industrial **byproduct POP** (Plaster of Paris) to add to conservation of mineral gypsum.
2. Optimum utilization of sub-grade limestone to further reduce the consumption of additives from **0.30% (07-08 level) to 0.20%** in raw mix preparation.
3. **8151 tons of bed material** generated from the CPPs was suitably used in cement manufacturing process.

▪ Fuel

1. In addition to the existing 5% usage of agro waste in old cement kiln, **additional 5%** consumption of **agro waste** has also been started in **Kiln-2** during the year 08-09.
2. About **16500 tons of high carbon fly ash** with **15% carbon** content generated from the old CPP was used in cement pyro-processing.
3. **1730 tons of CETP sludge** procured from Pali & **21474 Kgs. of spent oil/ grease** generated in-house were utilized (burnt) in cement kiln to recover their heat content.

▪ Blending material

In the year 2008-09, 144480 tons of extra PPC was produced by **utilizing 36120 tons (ADB) of Pond Ash** resulting into savings of **173376 kWh** electrical energy & **3566.34 tons of CO₂** (GHG emission). A separate system was also installed for feeding Pond Ash.

Other significant energy & environment saving measures in 08-09:

Project Description	Electricity (Lakhs (kWh))	Total savings in (Rs. Lakhs)	Investment incurred on the project (Rs. Lakhs)
Replacement of 700 Nos. of ordinary incandescent lamps with CFL	3.16	15.80	3.80
Installation of solar panels in Guest House & Canteen	0.438	1.74	1.60
Cement mill slide shoe lubrication pumps rewinded motors replaced with energy efficient motors	0.275	1.38	1.20
Optimized Bag House transport system with RA fan in both the units	0.351	1.76	Nil
Installed separate Alternate fuel conveying system to facilitate feeding of A/F in both the Kilns	-	127.80	80
Modification in wagon loading system	Rake loading time reduced by 3 hrs. causing proportionate reduction in sp. Power consumption of packers		83
Improved HP heater efficiency in CPP-II by replacing the 1" line with 3" line for full flow of HP heater condensate to deaerator	Heat cycle efficiency of TG improved		0.24
Provided charcoal feeding arrangement for CPP-II boiler light up	Reduction in diesel consumption from 11-12 KL to 7-8 KL per light up		0.012